



**BRUHAT BENGALURU MAHANAGAR PALIKE
ENVIRONMENTAL CELL, MARATHALLI SUB-DIVISION,
MAHADEVAPURA ZONE**

Office of the Environmental Engineer
BBMP, Marathalli Sub Division
Krishna Vibhav Building,
Marathalli Bridge, Bangalore-560037
Date: 01-06-2016


No: BBMP/MPZ/MSD/CR/72/2016-17

TO WHOM SO EVER IT MAY CONCERN

This is to certify that "Sri Chaitanya Techno School" # 8611 C Munnekolala main road, Marathalli, Bangalore-37 was inspected by me with senior health inspector on 01-06-2016 and it is to report as follows.

1. The school is conducted 2 blocks in 4 floors with 75 class rooms and is well ventilated.
2. Sufficient toilet facilities has been provided, separate for boys and girls and is maintained in order.
3. First aid facilities is being provided.
4. Hygienic drinking water facilities is provided.
5. Each floor has been provided with fire extinguisher.
6. Entire premises is well maintained with proper and routine cleaning.


Manager
SRI CHAITANYA TECHNO SCHOOL
BANGALORE-560 037


ENVIRONMENTAL ENGINEER,
MARATHALLI SUB-DIVISION
Marathalli Bridge, Bangalore
B S W.P. Mahadevapura Zone
Bangalore - 560 037


Principal
Sri Chaitanya Techno School
Marathahalli, Bangalore-560 037

No. 126/CFO/BNG-East/NOC/2016

Office of the Chief Fire Officer
Bangalore East
Kamataka State Fire & Emergency Service
No 4, Bahai Bhavan Road
BANGALORE-560 025
Dated: 01-06-2016

To,
The Principal,
Sri Chaitanya Techno School
No, 86/1C, Munnekolala,
Maratahlli,
Bangalore 560 037,

Sir,

Sub: Issue of Advice on requirement of fire prevention,
fire fighting & evacuation measures for Sri Chaitanya
Techno School, No. 86/1C, Minnekolala, Marathalli,
Bangalore-reg.

Ref: 1] Your Letter No. Nil Dated 01-06-2016.
2] Report No. 12/RFO/BNG-EastINOC/2016
Dated 01-06-2016.

« «O» »

The Regional Fire Officer, Bangalore East Range, Bangalore had from fire prevention, fire fighting and evacuation point of view, inspected the premises of Sri Chaitanya Techno School, No. 86/1C, Munnekolala, Bangalore 560037 on 01-06-2016, for suggesting fire prevention, fire fighting and evacuation measures. The details are as follows:-

A. Details of the Building.

1. Address of the premises

Sri Chaitanya Techno School
No. 86/1C, Munnekolala,
Marathalli,
Bangalore 560 037

2. Number of Building

one Building (Two Blocks).

3. Number of floors

Ground & 3 upper floors.

4. Floor wise details of occupancy:

Ground Floor

One Multifuction Hall, Two Chemistry
Lab, One Math Lab, One Indoor Games,
One Store room, One
Library, One Principle room, One Accountant
room, Two Computer room, 7 Class rooms.


Manager
SRI CHAITANYA TECHNO SCHOOL
BANGALORE-560 037


Sri Chaitanya Techno School
Marathahalli, Bangalore-560 037

(1)	(2)	(3)
8. Fire order	Not Displayed.	Notice boards, indicating 'with the details of action to be taken by the employees in case of an emergency/Fire shall be displayed near the staircase at each floor with telephone numbers of Mahadevapura Fire Station i.e. 22971541 & Central Fire Control Room i.e 22971500, 22971600 & 101 and of nearby Ambulance Service.
9. Fire Fighting Training.	Not trained.	At least 40% of employees shall be got trained in basic fire fighting at our R.A. Mundkur Fire & Emergency Services Academy, Bannerghatta Road, Bangalore.

Under the circumstance stated above, there is No Objection to run Education activities in your school building subject to the condition of providing additional fire fighting equipments and fire precautionary measures shown in column No.3 of part B. Therefore, the school management should comply Karnataka Fire & Emergency -Services Department conditions to provide additional equipments and then intimate to this office within 3 months positively without fail.

Yours faithfully,


CHIEF FIRE OFFICER,
Bangalore East
Karnataka State Fire & Emergency Service
BANGALORE - 560 025.

Copy to Regional Fire Officer, Bangalore East Range, Bangalore.

Copy with complements : Submitted to the Director-General of Police and Director General, Karnataka Fire and Emergency Services, Bangalore.


Manager
SRI CHAITANYA TECHNO SCHOOL
BANGALORE-560 037


Principal
Sri Chaitanya Techno School
Marathahalli, Bangalore-560 037